


PRECAST CONCRETE BASES

BASE TYPE	POLE TYPE	APPROXIMATE MASS	VOLUME OF CONCRETE	A	B	C (ANCHOR BOLTS)
D2	13.5m TYPE 2 POLES	2450 kg	1.0 m^3	216	305	4-1 1/4"ø x 48" (1220) GALVANIZED AISI / SAE 4140
E2	TYPE 1 AND 3 POLES	2410 kg	1.0 m^3	197	280	4-1"ø x 36" (915) GALVANIZED AISI / SAE 4140

NOTES

1. SEE STANDARD SPECIFICATIONS & SPECIAL PROVISIONS FOR ADDITIONAL INFORMATION.
2. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE NOTED.
3. SEE DRAWING SP635-1.1.8 FOR ADDITIONAL DETAILS.
4. SEE DRAWINGS SP635-1.4.1 TO 1.4.4 FOR BACKFILL REQUIREMENTS.

NOT TO SCALE

BRITISH COLUMBIA Ministry of Transportation and Infrastructure

No.	Revision	Date
F		
E		
D	GENERAL REVISIONS	APR 17
C	REBAR DRAWING REFERENCE REVISED	AUG 96
B	DRAWING NUMBER CHANGED	AUG 95
A	GENERAL REVISIONS	AUG 94

TYPES D2 AND E2 CONCRETE BASES (PRECAST)

Date Approved: 30/09/93 E.L. (Signature on File) — Chief Highway Engineer

SPECIFICATION DRAWING No. SP635-1.1.7

TRI KON Precast Concrete Products

Tri-Kon Precast Products Ltd.
601 Patterson Street West
Cranbrook BC V1C 6T3
250-426-8162
info@trikonprecast.com
trikonprecast.com


PRODUCT
Electrical
DRAWING
Types D2 and E2 Concrete Bases, Precast

WEIGHT

DRAWING NO.
SP635-1.1.7
SHEET
12 of 39
DATE
As per drawing
UNITS / SCALE
As per drawing

Request A Quote

Dimensions and specifications as per drawing. Confirm handling weights before lifting.
trikonprecast.com



No.	Revision	Date
F		
E	GENERAL REVISIONS	APR 20
D	GENERAL REVISIONS	APR 17
C	ELEVATION OF BASE TO FINISHED GRADE REV'D	AUG 96
B	REBAR ADDED	AUG 95
A	GENERAL REVISIONS	AUG 94

TYPE D2 AND E2 CONCRETE BASES (PRECAST)

Date	Approved	SPECIFICATION DRAWING No.
30/09/93	E.L. (Signature on File) Chief Highway Engineer	SP635-1.1.8

TRI KON Precast Concrete Products

Tri-Kon Precast Products Ltd.
601 Patterson Street West
Cranbrook BC V1C 6T3
250-426-8162
info@trikonprecast.com
trikonprecast.com

PRODUCT
Electrical
DRAWING
Type D2 and E2 Concrete Bases, Precast

WEIGHT

DRAWING NO.
SP635-1.1.8
DATE
As per drawing
SHEET
13 of 39
UNITS / SCALE
As per drawing

Request A Quote

Dimensions and specifications as per drawing. Confirm handling weights before lifting.
trikonprecast.com